

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 65

Dated: 04-02-2026

It is certified that an inspection team headed by Mr. Arun Chouhan (Asth. Engineer) from PHED inspected the Mahesh Memorial Public School, at In front of thesil Office, Balwari Road, Gandhwani Dist. Dhar (MP) on 30/01/26... (date of inspection) and on the basis of Water Test Report (Attached) bearing no 65 dated 04-02-2026 of Water Testing Laboratory, Gandhwani (PHED Lab) certified that the Mahesh Memorial Public School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 Year

Signature with Seal:

Name : Mr. Arun Chouhan

Designation : Astt. Engineer

Name & Address of the Office / Department :

Assistant Engineer
Public Health Engineering
Sub-Div. Manawar

To
Mahesh Memorial Public School
In front of thesil Office Balwari Road,
Gandhwani Dist. Dhar(MP)

WATER TESTING LABORATORY

WATER TESTING LABORATORY

P.H.E. SUB DIVISION MANAWAR

पत्र क्रं. 65 / स. यं. / लो. स्वा. यां. / उपखण्ड मनावर दिनांक 04-02-2026

Village - Mahesh Memorial Public School Gandhwani (borewell)

testing Date : 02.02.2026

S.No.	Parameter	Acceptable/ Permissible Limit and Unit	Result
(A) Physical & Chemical			
1	Colour	1/5Hazen	0
2	Odour	Unobjectionable	Unobjectionable
3	Manganese(Mn)	0.1/0.3mg/liter	—
4	Turbidity	1.0 TO 5.0 NTU	2.2
5	Ph	6.5 to 8.5	7.1
7	TDS	500 to 2000 mg/liter	429
8	Total Hardness	200 to 600 mg/liter	340
9	Calcium	75 to 200 mg/liter	59
10	Magnesium	30 to 100 mg/liter	46
11	Sulphate	200/400 mg/liter	44.0
12	Total Alkalinity	200 to 600 mg/liter	304
13	chlorides	250 to 1000 mg/liter	38
14	Fluorides	1.0 to 1.5 mg/ liter	0.8
15	Nitrates	45 to no Relaxation mg / liter	10.35
16	Iron	1 toNo Relaxation mg /liter	0.1
17	Residual chlorine	0.2to 1mg/liter	0.0
(B) Bacteriological			
18	Total Coliform	0/100ml	0.0
19	Feacal Coliform	0/100ml	0.0

रिमार्क— टेस्ट किये गये सेम्पल में सभी पैरामिटर तय सीमा के अन्दर है। अतः पानी पिने योग्य है। पेयजल स्रोत के आस-पास साफ सफाई रखे एवं समय पर क्लोरिनेशन करते रहें।




Chemist

P.H.E. Sub Dn. Manawar



Assistant Engineer

P.H.E. Sub Dn. Manawar



Sub Registrar